

**DIRC Water Plant Checklist:** (See DIRC call list for expert phone & pager contact numbers) 1/2005

<b>Look For Leaks And Note!</b>	DATE															
	SHIFT															
	INITIALS															

**Reverse Osmosis Unit (1)**

Is Power Light On?																
Switch In Automatic?																
R/O Pump Running? Y/N																
If Yes:																
Membrane Pressure<225 PSI?																
Permeate Flow About 2GPM?																
Concentrate Flow About 5GPM?																

**DI Water Distribution Panel (2)**

Power Light On?																
Pump #2 Selected?																
Run Light On?																
If No Run Light, Move Switch To Reset 1 Time, Then To operate. <b>If Still No Light, Call Expert.</b>																
<b>If Water Low Light Is On, Call Expert</b>																

**Water Degassing Panel (3)**

Power & Run Lights On?															
Mode Is Manual & Pump Is Running?															
Vacuum Reads 20"-30" Hg?															

**UV Light Source (4)**

Power Switch Is On?															
Blue Glow In The Plastic Tubing?															

**Water Tank (5)**

Water Level Within The OK Indicator?															
Output Flowmeters Read About 3GPM Total?															

**NOTES:**  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_