# ANNUAL ENVIRONMENTAL MONITORING REPORT

JANUARY - DECEMBER 1974

# HEALTH PHYSICS STAFF STANFORD LINEAR ACCELERATOR CENTER STANFORD UNIVERSITY Stanford, California 94305

# PREPARED FOR THE

# U.S. ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION

# UNDER CONTRACT NO. AT(04-3)-515

April 1975

# CONTENTS

	Page
Introduction and Summary	• 1
Monitoring Techniques and Standards	• 2
Monitoring Results	• 6
Nonradioactive Effluent Monitoring	. 9
Atmospheric Dispersion Model - Appendix A	. 17
Population Dose Assessment Model - Appendix B	. 19
References	. 23

• • •

#### INTRODUCTION

The Stanford Linear Accelerator Center (SLAC) is located two miles west of the Stanford campus in San Mateo County, California. Its boundaries include Sand Hill Road on the north and San Francisquito Creek on the south. The land slopes to the south toward San Francisquito Creek. The total length of the accelerator and experimental areas is approximately 3 miles and is oriented almost east-west. Figures 1 and 2 locate SLAC with respect to the surrounding vicinity.

SLAC is a large research laboratory devoted to theoretical and experimental research in high energy physics and to the development of new techniques in high energy accelerator particle detectors. The main tool of the laboratory is a 2 mile long linear accelerator. This accelerator produces beams of electrons with energies up to 22 billion electron volts (22 GeV). It can also accelerate positrons, the "anti-particles" of the electrons, up to 15 GeV. The work is carried out under the sponsorship and financial support of the U.S. Energy Research and Development Administration.

Authorization of the project was given by the U.S. Congress in 1961. Construction of the accelerator started in 1962 and was completed in 1966. Research consisting of numerous and varied experiments has been under way since late 1966.

#### Summary

Environmental monitoring results continue to demonstrate that, except for penetrating radiation, environmental radiological impact due to SLAC operation is not distinguishable from natural environmental sources. During 1974 the maximum neutron dose near the site boundary was 11.5 mrem. This represents about 12% of the annual dose from natural sources at this elevation and 2.3% of the technical standard of 500 mrem per person annually.<sup>1</sup>

There have been no measurable increases in radioactivity in ground water attributable to SLAC operations. Airborne radioactivity released from SLAC also continues to make only a negligible environmental impact and results in a site boundary annual dose of less than 1.7 mrem, which represents less than 1.7% of the annual dose from the natural radiation environment and about 0.34% of the technical standard.

### MONITORING TECHNIQUES AND STANDARDS

#### Concentration Guides for Liquid Effluent

Because of the nature of the radionuclides produced at SLAC, the appropriate Concentration Guide (CG) for liquid effluents is  $3 \times 10^{-6} \,\mu\text{Ci/ml}$ . This is true because none of the following isotopes is produced at SLAC: <sup>90</sup>Sr, <sup>125</sup>I, <sup>126</sup>I, <sup>129</sup>I, <sup>131</sup>I, <sup>210</sup>Pb, <sup>210</sup>Po, <sup>211</sup>At, <sup>223</sup>Ra, <sup>224</sup>Ra, <sup>226</sup>Ra, <sup>227</sup>Ac, <sup>228</sup>Ra, <sup>230</sup>Th, <sup>231</sup>Pa, <sup>232</sup>Th, <sup>248</sup>Cm, <sup>254</sup>Cf, <sup>256</sup>Fm, natural thorium.<sup>1</sup>

## Sample Analysis

All water samples collected are analyzed for gross beta activity and tritium by an independent laboratory. Analysis for alpha-emitting radioelements is not performed because we do not produce nor possess in unsealed form significant quantities of this type of radioactivity at SLAC.<sup>2</sup> In addition to routine gross beta analysis, SLAC examines aliquots of selected speciments by gamma spectroscopy if necessary.

#### Sample Preparation

When environmental water samples exhibit large amounts of insoluble solids, the solid fraction and filtrate activities are determined separately.

The total volume of each sample is measured and filtered. The original sample bottle is rinsed with the filtrate and the activity in each fraction is determined separately.

For the solid fraction, the filter paper and solid are dried at ~  $100^{\circ}$ C and weighed after cooling. A 300 to 500 mg aliquot is counted.

The filtrate and water samples exhibiting low solid content are treated the same. A 200 cc volume is taken from each 500 cc sample and evaporated to a smaller volume in a beaker. It is then transferred to a weighed planchet with dilute acid and water rinses. The sample is evaporated gently, weighed, and counted.

#### Gross Beta

The prepared samples are counted in a low-background proportional counter ( $\leq 1.5$  cpm). The results are normalized by comparison with the count of a known <sup>137</sup>Cs source.

Some samples require a correction for naturally occurring  ${}^{40}$ K. In that case, the total amount of potassium in the sample is determined by flame photometry. The amount of  ${}^{40}$ K activity can then be calculated, based on the per cent abundance of this naturally occurring radioelement and subtracted from the sample count. This correction is performed on water samples whose gross beta activity is greater than  $1 \times 10^{-7} \,\mu \text{Ci/ml}$ .

#### Tritium

To determine the tritium concentration, a 2-3 ml aliquot of the filtered solution from the gross beta sample preparation is accurately transferred to a liquid scintillation sample vial. The sample vial is placed in a liquid scintillation counting system. The limit of sensitivity at the 95% confidence level is  $\geq 3 \times 10^{-6} \,\mu \text{Ci/ml}.$ 

# Concentration Guides for Airborne Radioactivity

The Concentration Guides (CG's) for airborne radioactivity appear in Reference 1. They were derived from dose standards which require that no individual in the general population will be exposed to greater than 500 mrem in one year and that the average dose to a population of suitable size shall not exceed 170 mrem annually from project operations.

Airborne radioactivity produced as the result of operations is short-lived, i.e., the half-lives range from 2 minutes to 1.8 hours and are in gaseous (not particulate) form. These isotopes include the following:

Isotope	Half-Life	CG µCi/ml
<sup>15</sup> 0	2.1 min	$5 \times 10^{-8(a)}$
$^{13}$ N	9.9 min	$5 \times 10^{-8}$ (a)
<sup>11</sup> C	20.5 min	$5 \times 10^{-8(a)}$
$^{41}$ Ar	1.8 hr	$4 \times 10^{-8}$

#### TABLE 1

GASEOUS RADIOACTIVITY RELEASED TO ATMOSPHERE

(a) Calculated from Ref. 3, assuming total submersion.

Since we do not routinely release airborne radioactivity while the beam is on and require a waiting period before turning on the exhausters, the only radioisotope released is <sup>41</sup>Ar. By far the greater proportion of exposure an individual may receive, under any circumstances, from the radioelements listed in Table 1 is from whole body immersion. Thus for an individual to receive a whole body dose of 500 mrem annually requires an exposure to a large cloud of <sup>41</sup>Ar with average concentration of  $4 \times 10^{-8} \, \mu \text{Ci/ml}$  (Ci/m<sup>3</sup>) for an entire year.

- 5 -

#### Analysis Techniques for Airborne Radioactivity

The accelerator and beam switchyard (BSY) areas are vented by 20 fans: the discharge point is just slightly above roof elevation. The total exhaust rate for the accelerator is 60 m<sup>3</sup>/s and the BSY is 40 m<sup>3</sup>/s. The accelerator and BSY are not normally vented while the electron beam is on. If personnel entry has to be made during an operating cycle the area is vented for 10 minutes prior to entry and after the electron beam has been shut off. The release of radioactivity is therefore infrequent and only for brief periods of from 30-60 minutes. The accelerator does not represent a measurable source of gaseous or particulate radioactivity due to low activating potential.

Each ventilation fan is interlocked with a radioactive gas detector comprised of a Geiger-Mueller detector, power supply, rate meter, strip chart recorder, and air pump. The electronics are in continuous operation and the recorder and air pump are interlocked with the ventilation fan so that they operate only when the machine is being vented.

The gas monitors for the BSY collect particulate samples during venting and have revealed negative results. During this report period, no particulate radioactivity above background was detected. This agrees with previous "grab" samples collected in the exhaust stream.

### Penetrating Radiation Monitoring Techniques

Seven Peripheral Monitoring Stations (PMS) serve to provide continuously recorded data concerning radiation levels ( $\gamma$  and n) near SLAC boundaries. Their positions are located in Figures 3 and 4.

Radiation information is obtained with a Geiger tube for gamma detection, and a paraffin-moderated  $BF_3$  neutron detector calibrated with a PuBe neutron source. The resultant sensitivities are such that a  $\gamma$  flux from <sup>60</sup>Co exposed to an average value of 1 mR/hr for one hour will be recorded as  $\sim 10^4$  counts on the Geiger tube channel, and a neutron flux having an average value for one hour of 1 mrem/hr will be read out as  $\sim 10^5$  counts on the BF<sub>3</sub> channel. The hourly printout cycle of the Sodeco register is programmed by two clock motors with cam actuated switches and associated electronic circuitry. This programmer automatically interrupts data acquisition, generates a print command, resets the digits in parallel, and reverts to the normal condition of serial counting of incoming data pulses. Dead time per printout cycle is less than 20 seconds per hour.

In connection with the pulse pair resolution limitation of the Sodeco register mentioned above, an important feature of this system involves the pulser which drives the register. It is of the nonparalyzable type. This means that if the instantaneous counting rate (20 counts/sec) is ever exceeded the register will merely not count the pulses in excess of its maximum rate. It can count at this maximum rate continuously (72,000 counts/hr).

#### MONITORING RESULTS

#### **Penetrating Radiation Monitoring**

The measured annual dose to the general population from accelerator operations is almost entirely from fast neutrons and is characterized as skyshine from SLAC's research area. The total dose measured at each PMS location appears in Table 2. Estimates of individual and general population whole body dose can be calculated from the PMS data based on estimates of distance and population density near SLAC. Table 4 tabulates these results and the model is discussed in Appendix B.

- 6 -

## Monitoring for Airborne Radioactivity

During 1974, 9.1 Ci of short-lived gaseous radioactivity was released to the atmosphere from SLAC. Particulate samplers continue to demonstrate that radioactivity in this form is not released from SLAC. The total volume released and the time of release were  $3.2 \times 10^5$  m<sup>3</sup> and 9.8 hours, respectively. When corrected for dilution this resulted in an average off-site concentration of  $1.3 \times 10^{-10}$  Ci/m<sup>3</sup>. This concentration is compared to the CG for <sup>41</sup>Ar which is  $4 \times 10^{-8}$  Ci/m<sup>3</sup> and is 0.33% of the technical standard.

We emphasize that the model used to calculate off-site concentration applies to the plume centerline and is not corrected for vertical and horizontal plume spread. Also, the model is not corrected for wind direction or velocity. The estimate of off-site concentration is therefore conservative and overestimates the actual concentration at the site boundary by factors of 2 - 10.

#### Water Samples

Results of the environmental analysis for radioactivity found in water appear in Table 3 and are reported in  $\mu$ Ci/ml for gross beta nonvolatile radioactivity. Analysis of tritium is performed on all water samples but is not reported because all environmental samples analyzed exhibited a tritium content less than the minimum detectable level of  $3 \times 10^{-6} \mu$ Ci/ml.

Some of the peripheral wells (ground water) exhibit higher than normal concentrations of gross beta radioactivity and solids. This activity is due to naturally occurring radioactive potassium-40 and has been verified by flame photometry and gamma spectral analysis. The <sup>40</sup>K content in samples from W-1 are typically about  $2 \times 10^{-7} \,\mu \text{Ci/ml}$ , accounting for approximately 90% of the gross beta activity present. Only those samples whose concentrations are above  $1 \times 10^{-7} \,\mu \text{Ci/ml}$  are corrected for <sup>40</sup>K. One well has exhibited some

- 7 -

naturally occurring radioactive daughters of uranium.

In addition to the ground and surface water sampling stations previously reported, two composite water sampling stations have been added; these samples are from the sanitary and storm sewers whose daily effluent averages approximately 210 and 260 m<sup>3</sup> respectively. The sampling rate is fixed at 5 mf/min and represents a sampling fraction of approximately  $3 \times 10^{-5}$  of the total effluent volume. At the end of each calendar quarter an aliquot is collected and analyzed for gross beta and tritium radioactivity. Results for 1974 appear in Table 3. There has been no detectable increase of radioactivity in environmental samples since SLAC operations began in 1966.

#### NONRADIOACTIVE EFFLUENT

#### Waste Water

1

Waste water from SLAC is discharged in basically three directions:

- (1) Sanitary sewer
- (2) Storm sewer effluent is released to natural open ditches. The ditches conduct this water to San Francisquito Creek by surface flow or by seepage. Both these liquid effluents (1) and (2) eventually reach San Francisco Bay, about six miles to the east.
- (3) About 40% of the water leaves the site as water vapor, via the four cooling towers.

Typical amounts are  $20 \times 10^6$  Gals/year to the sanitary sewer,  $40 \times 10^6$  Gals/year to the creek, and  $40 \times 10^6$  Gals/year evaporated. In addition, an average of  $240 \times 10^6$  Gals/year fall as rain on the 472-acre site, also flowing to the creek. Thus the SLAC effluent to the creek is diluted by an average factor of 6 by natural runoff.

Continuous monitoring stations sample the effluents of both the sanitary sewer and the storm sewer and have been in operation since the summer of 1971. The sanitary sewer monitoring station is at Manhole #4, northeast of the Central Laboratory. All SLAC sanitary sewage flows through the point where the monitoring station is located. A pump continuously withdraws the effluent at the rate of 5 ml per minute, which is stored in drums at that point. At the end of each quarter the contents of the drums are mixed and 1 liter samples are removed for chemical radiological analysis.

It should be noted that the sampling rate is constant at all times regardless of the flow rate and thus tends to give relatively greater weight to the effluent at lower flow rates, when concentrations are likely to be higher, the method of sampling is likely to lead to an overestimate rather than an underestimate of concentrations.

#### Sanitary Sewer Effluents

About 20% of SLAC's domestic water supply is released to the sanitary sewer; the remaining 80% leaves the site by evaporation or via San Francisquito Creek. The sanitary sewer outlet at the northeast corner of the site is connected to the Menlo Park Sanitary District. The releases are ordinary sanitary wastes, and the Menlo Park treatment plant discharges its treated wastes directly into San Francisco Bay.

The quantity of discharge for 1974 was  $19.9 \times 10^6$  Gal. These amounts are not unusual in size for a facility employing about 1000 people, and do not constitute a burden on the Menlo Park Sanitary District. The amount is rather constant the year around, and relatively insensitive to the accelerator operating cycle.

#### Storm Sewer Effluents

Water effluent discharged into the storm sewer is a combination of (1) cooling tower blowdown, (2) water runoff from SLAC landscaping irrigation, (3) rainwater runoff during the winter, and (4) miscellaneous uses, mainly once-through cooling of various small systems.

About a quarter of the  $100 \times 10^6$  gallons of water per year used at SLAC flows as waste water to the creek.

The largest potential source of chemical effluents discharged to San Francisquito Creek is cooling tower blowdown water, discharged to three natural open ditches. There are four towers, of the induced-draft counterflow type. The primary system in all cases is a closed-loop, low-conductivity system. Tower 101 is located at the Central Utility Building and provides cooling for laboratories and shops of the Campus Area. Tower 1201 is adjacent to the accelerator and is meant to cool the injector, positron source, and the first accelerator mile. Tower 1202, also adjacent to the accelerator, cools the second mile, and tower 1701, near the Beam Switchyard and Research Area, provides cooling for these areas.

The cooling tower water is chemically treated with inorganic algaecides and corrosion inhibitors. However, beginning with 1975 these agents will no longer be used. Silica and an organic algaecide compounds have been substituted. The blowdown water is basically source water whose solutes are concentrated by a factor of 4 - 6.

The cooling tower effluents are subject to control by the U.S. Environmental Protection Agency (EPA), under Discharge Permit No. CA0005541, issued September 30, 1973, and the State of California Regional Water Pollution Control Board (RWPCB). The EPA Discharge Permit states the maximum permissible amounts and concentrations of total suspended solids, zinc (Zn), and net added phosphate ( $PO_4$ ), as well as maximum temperature and permissible range of pH. It sets forth a monitoring schedule describing the types of sampling and minimum frequency of analysis. Each tower's effluent is analyzed separately, and quarterly reports are filed.

#### MONITORING RESULTS

#### Sanitary Sewer

Concentrations of various elements found in quarterly analyses from the sanitary sewer are summarized in Table 5. Analyses performed for 1974 are

- 11 -

compared with an applicable standard, namely the General Regulation No. 51 of the Menlo Park Sanitary District, Menlo Park, California, as amended November 12, 1973. Through its contract, SLAC is legally obliged to meet the broader standards of the regulations set forth in 1957. The more detailed comparison with the 1973 standards is therefore an informal comparison only.

#### Storm Sewer

Results of water monitoring efforts during 1974 appear in Table 6. These results show compliance with the specified standards appearing in EPA Discharge Permit No. CA0005541, with the exception of zinc. As mentioned before, we have substituted other chemicals for water treatment, and the zinc and phosphate concentrations will show a steady decline in future weeks.

Monitoring results for Cooling Tower 101 are not reported, because this effluent was recycled for use as cooling water at SLAC during 1974.

# ANNUAL PENETRATING RADIATION DOSE EQUIVALENT MEASURED NEAR SLAC'S BOUNDARIES

#### 1974

		Gamma		<u>_</u> 1		%	
PMS	Background + Source	Background	Source	Background + Source	Background	Source <sup>(d)</sup>	Standard (b)
1	88	86	(a)	16.5	8.8	7.7	1.5
2	65	64	(a)	13.5	8.8	4.7	0.9
3	64	60	<b>(</b> a)	13.5	8.8	4.7	0.9
4	(c)			15.0	8.8	6.2	1.2
5	(c)			20.3	8.8	11.5	2.3
6	76	75	(a)	10.5	8.8	1.7	0.3
8	70	69	<b>(</b> a)	17.0	8.8	8.2	1.6

(a) Difference between gamma background radiation and source contribution fall within normal variation of background values and are all consistent with zero. Because these values are the difference between relative large numbers, each having fluctuations, negative numbers may occur.

(b) Standard from U.S. Energy Research and Development Administration Manual, Chapter 0524, 500 mrem per year.

(c) Station out of service.

(d) Owing to uncertainties in the neutron spectrum at the site boundary, and in the assignment of a quality factor, the neutron dose may be overestimated by a factor of 2 (see text).

# MEASURED RADIOACTIVITY CONTENT OF ENVIRONMENTAL SAMPLES COLLECTED AT SLAC FROM JANUARY THROUGH DECEMBER, 1974

	Total	Gross	%		
Sample	Sample Samples Minir		Maximum	Average	Standard <sup>(1)</sup>
Well Water, µCi/ml	13	$3 \times 10^{-9}$	$1.4 \times 10^{-7}$	$2.5 \times 10^{-8}$	(b)
Sanitary Sewer, $\mu$ Ci/ml	3(c)	$6 \times 10^{-9}$	$2.7 \times 10^{-8}$	$1.8 \times 10^{-8}$	(b)
Storm Sewer, $\mu$ Ci/ml	3(c)	$8 \times 10^{-9}$	$1.4 \times 10^{-8}$	$1.4 \times 10^{-8}$	<b>(</b> b)

(a) Includes  $^{40}$ K.

(b) Does not apply: all samples consistent with background only.

(c) 1  $\ell$  aliquot sample from  $2 \times 10^6$  ml volume.

### TABLE 4

Exposure	Maximum Annual	Percent of	Man-Re	Man-Rem Estimate			
Pathway	mrem	Standard	SLAC	Background			
Penetrating	11.5 <sup>(a)</sup>	2.3	5.3	204			
Water	<b>(</b> b)	<b>(</b> b)	<b>(</b> b)	$\int_{50} (d)$			
Airborne	$\ll 1.7$	≪0.33	(c)				
Total	11.5	2.3	5.3	250			

### SUMMARY OF RADIATION MEASUREMENTS BY PATHWAY DURING CALENDAR 1974

(a) Maximum measured value at PMS 5.

(b) Does not apply, all samples revealed background levels.

(c) Below significant level.

(d) 25 mrem per person for internal dose from natural radioactivity<sup>(5)</sup> or  $\sim 50$  man-rem to population near SLAC.

# AVERAGE CHEMICAL CONCENTRATIONS OF SANITARY SEWER EFFLUENT

# FOR FOURTH QUARTER 1974

	mg/1						
	Concentration Standa						
Arconia (An)	0.015	0 1					
Barium (Ba)	<0.05	5.0					
$\frac{\text{Dallum}}{\text{Calleron}}$	0.01	5.0					
SIIVER (Ag)	0.01	5.0					
Bervllium (Be)	<0.2	1.0					
Boron (B)	<0.1	1.0					
Zinc (Zn)	1.9	5.0					
Chlorine, Available							
residual	<0.1	50.0					
Cadmium (Cd)	<0.01	0.1					
Chromium, Hexavalent	<0.002	1.0					
·····							
Chromium Total (Cr)	0.04	2.0					
Cobalt (Co)	<0,05	1.0					
Copper (Cu)	1.4	1.0					
Cresols	None detected	2.0					
Cvanide (CN)	0.18	1.0					
Fluoride (F)	0.32	1.5					
fidoride (f)	0.52	1.2					
Formaldehvde	0.02	5.0					
Lead (Pb)	<0.05	0.5					
Manganese (Mn)	<0.05	1.0					
Mercury (Hg)	0.0002	0.05					
Nickel (Ni)	0.36	1.0					
Organic Solvents	None detected	50.0					
-							
Chloroform	None detected	50.0					
Phenols	<0.01	1.0					
Selenium (Se)	0.02	2.0					

# NONRADIOACTIVE EFFLUENT DISCHARGE MONITORING REPORT

1974

Parameter	Sample Frequency	Range or MDL	Units	Stand	<u>Cool</u> Min	ing Towe <u>Max</u>	r 1201 <u>Aver</u>	<u>Cool</u> Min	ing Towe <u>Max</u>	r 1701 Aver	<u>Cooli</u> <u>Min</u>	ng Tower <u>Max</u>	1202 Aver	
FLOW	Continuous	Meter	Ga1/d	NA	2930	17,650	10,197	2216	16,820	8962	626	10,387	6194	
рН	Continuous	0.1-14.0		6.0-9.0	7.3	8.9	8.3	6.3	7.6	6.9	6.1	7.3	6.8	
TEMPERATURE	Daily	0.5	°F	85	40	84	67	41	80	66	39	84	69	
ZINC	Monthly	0.001	mg/1	1.0	<0.01	1.6	0.3	0.7	4.8	1.9	0.3	5.1	1.9	
Phosphorous	Monthly	0.01	mg/l	12.0	0.15	4.8	1.85	0.92	8.0	3.4	1.2	6.7	3.1	
Settlable Solids	Monthly	<u>&gt;0.1</u>	mg/1	0.1	<0.1	4.0	0.17	<0.1	0.5	0.2	<0.1	0.5	0.2	- 16 -
Total Suspended Solids	Monthly	<u>&gt;</u> 0.1	mg/l	20	2	39	12	<1.0	50	20	6	24	10	

···· ··-.

MDL is minimum detectable level of concentration analyses.

NA - not applicable.

1 -

#### APPENDIX A

## Atmospheric Dispersion Model

In 1966 an independent evaluation of meteorological regimes at SLAC was performed.<sup>4</sup> From this study an empirical mathematical model was developed. The model that is used predicts the centerline concentration very well but overestimates the total dosage values.

$$\frac{\chi_p}{Q} = \frac{G}{u} \frac{X}{X_0}^{-1.75 + \frac{b(1-C)}{u}}$$

)

where  $\chi_p$  = centerline concentration (Ci/m<sup>3</sup>)

$$Q = source strength (Ci/s)$$

 $G = 8 m^{-2}$ 

u = mean wind speed (m/s)

X = distance from source (m)

$$X_0 = 2m$$

C = fraction of sky covered by low clouds

$$b = 0.5 \text{ m/s} (\text{day}); b = -1.2 \text{ m/s} (\text{night})$$

Figure 5 summarizes peak dosage per unit source strength as a function of wind speed and atmospheric stability at a fixed distance of 400 meters (roughly the distance from the source to SLAC's boundaries). To characterize atmospheric stability, the degree of cloud cover is indicated for day and nightime regimes. This method is based upon Pasquill's data for cloud expansion for various stability categories.

For a wind speed of 2m/s atmospheric dilution factors -- for determining centerline concentrations -- range between  $2 \times 10^{-5}$  and  $1.5 \times 10^{-3}$ . For purposes of estimating radiation dose at the site boundary, neutral conditions are

assumed and a generally conservative dilution factor of  $4.5 \times 10^{-4} \text{ s/m}^3$  is used in the calculation of average concentration at the site boundary. (See Fig. 5, Curve 1.0.)

#### APPENDIX B

#### Model for Potential Dose Assessment

According to Chapter 0513, "Effluent and Environmental Monitoring and Reporting," an assessment of whole body man-rem dose to the general population within 50 miles (80 km) of SLAC is required. Our site boundary dose due to accelerator operation is detectable and is < 20 mrem per year from penetrating radiation. Integrating a population dose of small values out to 50 miles becomes an exercise in numerical analysis that results in questionable dose estimates. This is true because of the questionable assumptions that must be made to explain the behavior of neutrons at large distances from the source. We have therefore modified the distance term to include individual annual doses down to 1 mrem, which corresponds to a distance of <1 mile from a central point representative of the source of neutrons. The 1 mrem value is approximately 1% of the total natural background dose and any further extrapolation is unjustified because the difference in population dose from natural background and SLAC operations cannot reasonably be determined.

There are three major pathways leading to human exposure: (1) airborne, (2) food chain, and (3) direct exposure to penetrating radiation. Of the three major pathways listed above, only direct exposure to penetrating radiation is of any significance from SLAC operations. The source of this exposure is from neutrons resulting from the absorption of high energy electrons and photons in the experimental area creating energetic particles, some of which escape from the heavily shielded areas.

In order to make an accurate and realistic assessment of radiation exposure to the public at low doses it is necessary that exposure from the natural radiation environment be known. This is true because the instruments used for this purpose respond to natural radiation sources as well as man-made sources and the portion due to natural radiation must be subtracted from the raw results. The population exposure assessments appearing in this document are in all cases overstatements of the true impact and the resulting values are representative of an upper limit of the possible range.

While the annual neutron dose from accelerator operations at the site boundary is measurable, it amounts to 5 - 10% of the total annual individual dose from natural background radiation. According to an EPA report, the average annual dose from cosmic, terrestrial and internal radiation in California is 125 mrem.<sup>5</sup> For purposes of comparison we have rounded this number off to 100 mrem.

Another quantity of interest is the population dose in units of man-rem. This is simply the product of the average individual dose and the total population exposed. For example, if there are 2000 people exposed to an average annual background dose of 0.1 rem (100 mrem) then the population dose is  $0.1 \times 2000$  or 200 man-rem from natural background radiation. The annual variation of exposure to natural background radiation may vary by  $\pm 20\%$ , largely caused by the difference of naturally occurring uranium, thorium, and potassium present in the ground and in building materials where people live and work. This value is also affected by weather conditions which may increase or decrease the amount of radon/thoron present in the atmosphere at any given time.

There are two major problems associated with this technique that affect overall accuracy of the measurement. First, the conversion of neutron flux to dose requires that the spectrum of neutrons at the point of measurement be known. In order to characterize the spectrum much larger fluxes must be

- 20 -

available than are currently produced by the SLAC machine at the site boundary. Since the quality factor (QF) is a function of energy we have selected a QF of 10 as best characterizing the energy spectrum produced by SLAC. We feel that this is an overestimate by a factor of approximately 2. This degree of conservatism overestimates the actual dose, also by a factor of approximately 2, and the dose assessment that appears in this document could be divided by 2 if the spectrum were known. Until a useful experiment can be performed, with neutron yields of sufficient intensity, the QF cannot be determined with any better precision, and a conservative value is used.

A second problem with this sort of extrapolation is the behavior of neutrons at large distances. Most of the high energy accelerator laboratories have made measurements and have derived formulas for predicting this behavior.<sup>8</sup> Unfortunately all such measurements are unique to each facility because of design differences, type of machine, and surrounding topography. Here again we have chosen a conservative formula for calculating the dose at distances other than the point of measurement. Lindenbaum<sup>6</sup> gave a method for evaluating skyshine neutrons which was later verified by Ladu et al.<sup>7</sup> using Monte Carlo techniques. Lindenbaum approximated the falloff by  $e^{-R/\lambda}/R$  where R is in feet and  $\lambda = 830$  feet. This equation fits the SLAC data fairly well, and is the one used to predict doses beyond our measuring station (Fig. 6). In order to derive a correction for large distances unique for SLAC we will need a much larger intensity to determine a more precise correction for distance. We feel that the methods used and reported in this document may overestimate the true population dose by as much as a factor of 2.

The population activity close to SLAC, i.e., within 1 mile, is a mixture of commerce and residential dwellings. The occupancy factor - the proportion of

- 21 -

time throughout the year that these structures were occupied - is assumed to be 1/4 for business activities and 1.0 for private dwellings. The number of people were estimated for each type of structure, multiplied by the occupancy factor, and summed to estimate the total population that might be continuously present. (See Fig. 4.)

From this estimate and the measured radiation dose near the site boundary we can estimate both the average individual dose and the population dose from SLAC operations. For 1974 we arrive at 2040 persons who are included in the pool exposed to 1 mrem or more for calendar year 1974. The man-rem dose was 5.3 man-rem and the average individual dose was 2.6 mrem or less than 3% increase over natural background radiation.

#### REFERENCES

- 1. U.S. Energy Research and Development Administration Manual, Chapter 0524, Standards for Radiation Protection.
- W. R. Nelson, "Radioactive Ground Water Produced in the Vicinity of Beam Dumps," Stanford Linear Accelerator Center Report No. SLAC-TN-65-16 (July 1965).
- 3. Recommendations of the International Commission on Radiological Protection, Publication 2 (Pergamon Press, London, 1959).
- J. A. Murray, L. M. Vaughan, and R. W. McMullen, Atmospheric Transport and Diffusion Characteristics for Selected Daytime Meteorological Regimes at SLAC, Memorandum Report No. 326-1, Metronics Aerosol Laboratory, 21 December 1967.
- 5. "Estimates of Ionizing Radiation Doses in the United States, 1960-2000,"
  U.S. Environmental Protection Agency Report No. ORP/CSD 72-1 (1972).
- 6. S. J. Lindenbaum, "Shielding of High Energy Accelerators," Int. Conf. on High Energy Accelerators, Brookhaven, 1961.
- 7. M. Ladu et al., "A Contribution to the Skyshine Study," Nucl. Instr. and Meth. 62, 51 (1968).
- 8. T. M. Jenkins, "Accelerator Boundary Doses and Skyshine," Health Physics 27, 251 (1974).

External Distribution:

Gordon Facer, MAERDA-HQAndrew J. Pressesky, RDTERDA-HQ, Asst. Dir. for Nuclear SafetyJames Miller, BERERDA-HQERDA-HQ Library<br/>Attn: Charles ShermanERDA-HQJack L. BrownBRH-CALIFRegional AdministratorEPA Region IX









FIG. 2--Air view of SLAC site showing the two-mile accelerator, the research facility, and the principal laboratories and shops. .

---





FIG. 4--SLAC research yard and surrounding community.

-- -- -



FIG. 5--Centerline dilution factor for various atmospheric conditions as a function of wind speed.



- 29 -

FIG. 6--Measurements made along a line between ESA and site boundary.